

# DIABLO WATER DISTRICT - SUBMITTAL LOG

SUBMITTAL LOG # \_\_\_\_\_



PLEASE SKIP NUMBERS THAT DO NOT APPLY

\*\* PLEASE VISIT [www.diablowater.org](http://www.diablowater.org) \*\*  
FOR THE LATEST UPDATES

Subdivision or Project: \_\_\_\_\_

Submittal Number	Specification Reference	Drawing Reference	Submittal Description	Date Received From	Returned Response	No Exceptions Taken	Make Corrections Noted- <i>No need to re-submit</i>	Amend & Resubmit	Rejected	Submittal Required but not Received
				Contractor	DWD					
1-A	02231-2.01.A	DWD 5	Bore and Jack Casing							
2-A	02231-2.01.D	DWD 5	Bore and Jack Insulators: Calpico Model W / Williamson M-2, stainless steel bands and hardware							
3-A	02512	DWD 6	Double Offset: Minimum I.D. shall be nominal Include Size							
4-A	02512	DWD 7	Single Offset: Minimum I.D. shall be nominal Include Size							
5-A	02610-2.01.A	--	Ductile Iron Pipe: U.S. Pipe / American Cast Iron / Clow Pacific States or Approved Equal							
6-A	02610-2.01.B	--	Flanged Coupling Adapters: Smith-Blair Type 913 with EPDM gaskets or Approved Equal							
7-A	02610-2.01.B	--	Sleeve/Mechanical Couplings for Ductile Iron Pipe: Dresser 38 or 138, EPDM gaskets							
8-A	02610-2.01.B&C 02620-2.02.F	--	Push on Ductile Iron Pipe Fittings: Sigma / Tyler / Star							
9-A	02610-2.01.B&C 02620-2.02.F	--	MJ Ductile Iron Pipe Fittings: Star / Sigma / Tyler							
10-A	02610-2.01.B&C 02620-2.02.F	--	Flanged Ductile Iron Pipe Fittings: Sigma / Tyler / Star							
11-A	02610-2.01.B.1	--	Locking Joints for Ductile Iron Pipe: Field Lok 350 by U.S. Pipe Fitting							
12-A	02620-2.02.E	--	C900 PVC Pipe: Vinyl Tech /Royal Group or North American							



Subdivision or Project: \_\_\_\_\_

Submittal Number	Specification Reference	Drawing Reference	Submittal Description	Date Received From	Returned Response	No Exceptions Taken	Make Corrections Noted- No need to re-submit	Amend & Resubmit	Rejected	Submittal Required but not Received
				Contractor	DWD					
13-A	02620-2.03.A	DWD 1	No. 12 Copper Detection Wire: Solid with blue insulation							
14-A	02620-2.03.B	DWD 1	Plastic Warning Tape: Blue, minimum 6-inch							
15-A	02620-2.02.D.3	--	Sleeve/Mechanical Couplings for PVC Pipe: Hymax Coupling, Dresser 253, long style, EPDM gaskets							
16-A	02675	--	Disinfection Test Plan							
17-A	02830-Part 2	DWD 14	Fence Materials							
18-A	15100-2.03.D	DWD 15 DWD 17	Gate Valves: Mueller with stainless steel trim and hardware							
19-A	15100-2.04. H & J	DWD 19	Butterfly Valves: Mueller Lineseal III Class 150B, no equal certified with serial number, Interior with EPDM rubber seat							
20-A	15100-2.05.C	--	Ball Valves: Watts Series B-6000/Mueller B20200 Must be Lead Free							
21-A	15100-2.06.A	--	Insulating Fittings: Watts Regulator Co.							
22.1-A	15100-2.07.A	DWD 15	Fire Hydrants: Clow 960							
22.2-A	15100-2.07.D	DWD 15	Fire Hydrants: Two coats of Rust-oleum V7400 Safety Yellow							
22.2-A	15100-2.07.E	DWD 15	Fire Hydrants: NSF 61 Approved Lubricant							
23-A	15100-2.07.B	DWD 15	Hydrant Check Valve and Break Off Spool: Clow LB400							
24-A	15100-2.07.C	DWD 15	Ductile Iron Hydrant Bury: Sigma or South Bay							



Subdivision or Project: \_\_\_\_\_

Submittal Number	Specification Reference	Drawing Reference	Submittal Description	Date Received From	Returned Response	No Exceptions Taken	Make Corrections Noted- No need to re-submit	Amend & Resubmit	Rejected	Submittal Required but not Received
				Contractor	DWD					
25-A	15100-2.08.B	DWD 23 or DWD 20	ARV: Crispin UL10.1 / Apco 143C							
26-A	15100-2.08.B	DWD 20	ARV Screen: Christy 1" FPT #10 or DWD approved equal							
27-A	15100-2.08.B	DWD 23	Angle Valve for ARV: Mueller B-24258							
28-A	15100-2.08.B	DWD 23 or DWD 20	ARV Concrete Box and Lid: Christy B36 with extension							
29-A	15100-2.09	DWD 21	Blowoff Piping and Fittings: Brass for 2"							
30-A	15100-2.09.D	DWD 21	Angle Valve for Blowoff: Mueller B-24286 for 2"							
31-A	15100-2.10.A	--	Dielectric Unions and Flange Unions: EpcO Inc.							
32-A	15100-2.10.D	--	Flanged Coupling Adapters: Dresser Style 127 or 128 / ITT / Baker, stainless steel hardware							
33-A	15100-2.10.E.4	--	MJ Joint Restraint: EBAA Iron Megalug							
34-A	15100-2.10.E.2	--	Pipe Restraining Clamp Assemblies: Stellar Corporation							
35-A	15100-2.10.F or 02610-2.01.B.2	--	Flange Gaskets: Garlock 3760-U							
36-A	15100-2.10.F	--	Stainless Steel Bolts and Nuts F-593C or D shall be stamped on head of bolt							
37-A	15100-2.10.F	--	Protective Tape Wrap: 10 Mil Tape							
38-A	15100-2.10.G	DWD 17	G5 Valve Boxes: Christy Include "Water" on lid							

Subdivision or Project: \_\_\_\_\_

Submittal Number	Specification Reference	Drawing Reference	Submittal Description	Date Received From	Returned Response	No Exceptions Taken	Make Corrections Noted- No need to re-submit	Amend & Resubmit	Rejected	Submittal Required but not Received
				Contractor	DWD					
39-A	15100-2.10.G	DWD 17	G12 Valve Boxes: Christy Include "CP Test" or "Water" on lid							
40-A	15100-2.10.H	--	Tapping Sleeves: Up to 18" - JCM 432, all stainless materials and hardware Over 18" - Contact DWD							
41-A	15400-2.01.A&B	DWD 8	Up to 1" Copper Service Piping: Type K Soft, Polycoated Mueller Streamline Over 1" Type K Soft Mueller Streamline							
42-A	--	--	Above 1" Copper Service Line Poly Wrap: Blue							
43-A	15400-2.01.C	DWD 8	Service Saddles for PVC Pipe:  Mueller, cc thread, bronze, wide band							
44-A	15400-2.01.C	DWD 8	Service Saddles for Ductile Iron Pipe: Mueller, cc thread, full circle stainless steel							
45.1-A	15400-2.02.A	DWD 8	5/8" - 1" Flow Meter: Sensus SR11 Low Lead flow meter (CF)							
45.2-A	15400-2.02.B	DWD 8	1-1/2" - 2" Flow Meter: Sensus Omni C2 flow meter (CF) with							
45.3-A	15400-2.02.C	DWD 8	3" & 4" Flow Meter Sensus Omni C2 flow meter (CF)							
46-A	15400-2.02.A 15400-2.02.B 15400-2.02.C	DWD 8	520M-FlexNet MTX Unit							
47-A	--	DWD 8	Straight Meter Coupling: Mueller H-10892 Meter coupling: H1089ON							
48-A	15400-2.03	DWD 8 DWD 9 DWD 10	Meter Boxes: Christy B-12, B-16, B-30, B-40, or B-44 Lid for B-12 Box: B12P Lid for B-16 Box: B16P Lid must read "WATER" Lid must incorporate FlexNet 520M							



Subdivision or Project: \_\_\_\_\_

Submittal Number	Specification Reference	Drawing Reference	Submittal Description	Date Received From	Returned Response	No Exceptions Taken	Make Corrections Noted- No need to re-submit	Amend & Resubmit	Rejected	Submittal Required but not Received
				Contractor	DWD					
49-A	15400-2.03.B	DWD 8 DWD 20	1" Angle Meter Stops: Mueller B-24258							
50-A	15400-2.03.B	DWD 8	1-1/2" - 2" Angle Meter Stops: Mueller B-24276							
51-A	15400-2.04 or 16640-1.04.D	DWD 8 DWD C24	1" - 2" Corporation Stops: Mueller B-25008 Metalic water main-Muller insulated corp P# N35008							
52-A	15400-2.05.B	DWD 10	3/4" - 2" Double Check Valve: Febco LF850U (Must be Lead Free) 1/4" MIP 1/4" Flare Adapter Test Fitting							
53-A	15400-2.05.C	DWD 11	3/4" - 2" Reduced Pressure Backflow Preventer: Febco LF825YA RP with ball valves 1/4" MIP 1/4" Flare Adapter Test Fitting (Must be Lead Free)							
54-A	15400-2.05.C	--	Backflow Fittings: Must be Lead Free Brass							
55-A	15400-2.05.C	DWD 11	Backflow Cage & Freeze Cover sized for device & cage BPD1 Guardshack two-piece enclosure hinged, similar to Cage #GSM1 modified per DWD drawing on file with BPD1, powder coated Stainless Steel, Forest Green							
56-A	15400-2.05.C	DWD 12	2-1/2" - 10" Reduced Pressure Backflow Preventer: Febco LF880V N-shape w/Setter							
57-A	15400-2.05.D	DWD 13	2 1/2" - 10" Double Check Detector Valve: Febco LF876V N-shape w/Setter							
58-A	16640-1.03 to 1.05	--	Corrosion Control Design After Rough Grading							
59-A	16640-Part 2	DWD C1- DWD C29	Corrosion Control Products							
60-A	--	--	Bitumastic							