



87 Carol Lane/P. O. Box 127
Oakley, CA 94561
Phone: 925-625-3798
Fax: 925-625-0814
www.diablowater.org

SERVICE INSPECTIONS & BACKFLOW PROCEDURES

- Once all of the connection fees have been paid and the meter, MXU, and backflow have been installed as per DWD specifications, send an email to inspections@diablowater.org to schedule the inspections. Once the services have passed inspection, the developer must send an email to development@diablowater.org with the backflow testing schedule and the provide at least 48 hours notice prior to the backflow test.
 - Diablo Water District will unlock and turn on the water service the day of the testing by noon but will turn the service off at the Number 2 valve.
 - The certified backflow tester will test the backflow and if it passes, the certified tester may turn on the Number 2 valve. If it fails, then the tester must notify development@diablowater.org of the failed test and contact the Developer to notify them repairs are necessary.
 - The certified backflow tester must turn in the certified testing reports by 8am the following day of the service being unlocked to our office located at 87 Carol Lane, Oakley; fax to 925-625-0814; or email to development@diablowater.org. The testing reports MUST include the following:
 - Developer Name
 - Subdivision Name & #
 - Street Address & Lot #
 - Meter #
- Please note: If the certified reports are not received by 8am the following business day, the service(s) will be turned off and locked. If the services are turned off, it will be at the expense of the developer/contractor to have them re-tested.***
- After the certified reports are submitted to Diablo Water District, the service will be put into the Developer's name and billing will begin that day.
 - **Any tampering with a service that has NOT been unlocked by a Diablo Water District employee will be charged a \$500 tampering charge per service. If there are any questions whether a service is permitted to be used, please email development@diablowater.org.**